

CERTIFICATE OF ANALYSIS

Goods Name: R134A	Lot No: SW631240966
Sample Weight: 13.6KG	Sample Time: November 15. 2024
Sample Place: NO.1 WORKHOUSE	Report Time: November 15. 2024
Place of Origin: Shandong China	

ANALYSIS RESULT

COMPLEXION:	CLEAR AND COLORLESS
SMELL:	NO UNCOMMONLY
ODORS CHLORIDE	<0.0003
PURITY:	99.95%
NON CONDENSABLES(% BY VOLUME)	0.6
WATER(% BY WEIGHT)	0.00088
ACIDITY(% BY WEIGHT)	<0.0001
HIGH BOILING RESIDUE(% BY WEIGHT)	0.0006
TOTAL CHLOROFLUORO	PASS
UNSATURATES(% BY GC AREA)	0.0010

Remarks: EXCELLENT GRADE

Analyst: LIYUE

Checker: WENHANCHAO



Pureon Refrigerant Gases Pvt. Ltd.



+971551164289
+971522807537



www.pureon.ae
info@pureon.ae



The Meydan Hotel, Grandstand, 6th floor,
Meydan Road, Nad Al Sheba, Dubai, U.A.E