

CERTIFICATE OF ANALYSIS

Goods Name: R32	Lot No: SW631240966
Sample Weight: 9.5KG	Sample Time: November 15. 2024
Sample Place: NO.1 WORKHOUSE	Report Time: November 15. 2024
Place of Origin: Shandong China	

ANALYSIS RESULT

COMPLEXION:	CLEAR AND COLORLESS
SMELL:	NO UNCOMMONLY ODORS
CHLORIDE	PASS
PURITY:	99.98%
NON CONDENSABLES(% BY VOLUME)	0.79
WATER(% BY WEIGHT)	0.0008
ACIDITY(% BY WEIGHT)	NO
EVAPORATING RESIDUE(% BY WEIGHT)	0.0007

Remarks: EXCELLENT GRADE

Analyst: LIYUE

Checker: WENHANCHAO



Pureon Refrigerant Gases Pvt. Ltd.



+971551164289
+971522807537



www.pureon.ae
info@pureon.ae



The Meydan Hotel, Grandstand, 6th floor,
Meydan Road, Nad Al Sheba, Dubai, U.A.E